


Retained Material:-Lightweight Material AoR = 35 degrees Maximum Density 10 kN/m3 (1000 kgs/m3)

It is up to the client to advise if these parameters are not correct.

# **Design Parameters**


(1.50)

# NOTE:The bearing pressure beneath the wall is shown below. It is up to the client to ensure the ground is adequate.



Bearing Pressure
Beneath 300x1000mm Foundation
(1:25)

## **IMPORTANT NOTE:-**



Foundation Details
(1:25)

#### NOTES:-

- 1. The contractor should take all necessary measurements on site.
- 2. All dimensions shown on this drawing are approximate and for structural calculation purposes only.
- 3. Dimensions on this drawing should not be used for fabrication purposes.
- 4. Do not scale this drawing.
- 5. This drawing should be read in conjunction with the calculations.

### **IMPORTANT NOTE**

The existing slab and ground have not been investigated by CLP structures, the pressures exerted on the ground are shown on this drawing, however it is up to the client to satisfy himself that the existing ground is adequate to support these loads.

| Rev | Description      | Ву  | Date | Chk'd |
|-----|------------------|-----|------|-------|
|     |                  |     |      |       |
|     |                  |     |      |       |
|     |                  |     |      |       |
|     |                  |     |      |       |
|     |                  |     |      |       |
|     |                  |     |      |       |
|     | Purpose of Issue | Rev | Date | Auth  |



STRUCTURAL ENGINEERING CONSULTANTS

EMAIL: mail@CLP-Structures.co.uk

TEL: 0117 3706357

Client

Elite Precast Concrete Ltd.

Project

Lightweight Material 2.7m High — Duo Blocks

Title

Suggested Foundation Design

| Original Scale<br>As noted | Drawn Re<br>CEL<br>Date June 2017 | ev — Checked |  |  |
|----------------------------|-----------------------------------|--------------|--|--|
| Drawing Number 594-09 - 02 |                                   |              |  |  |

А3