Important Note - The retained material should be allowed to naturally fall against the wall as it is stacked. Do not allow the retained material to stand up on its own as this could lead to a catastrophic failure of the material and the wall.
The wall has not been designed to withstand the impact of the retained material suddenly falling against the wall due to incorrect loading.



Retained Material:-
Level Food Wastel to 3.5m High.
AoR = 35 degrees
Maximum Density
6 kN/m3 (600 kgs/m3)

It is up to the client to advise if these parameters are not correct.

Design Parameters
(1:50)



Bearing Pressure
Directly Beneath Wall



Bearing Pressure
Beneath 150mm slab

Bearing Pressures
(1:25)

NOTES:-
1. The contractor should take all necessary measurements on site.
2. All dimensions shown on this drawing are approximate and for structural calculation purposes only.
3. Dimensions on this drawing should not be used for fabrication purposes.
4. Do not scale this drawing.
5. This drawing should be read in conjunction with the calculations.

IMPORTANT NOTE
The existing slab and ground have not been investigated by CLP structures, the pressures exerted on the ground and slab are shown on this drawing, however **it is up to the client to satisfy himself that the existing ground and slab are adequate to support these loads.**

IMPORTANT NOTE
The wall has been designed to retain a specific material with a specific density and angle of repose. It is up to the client to ensure that the material retained on site does not exceed these designed parameters, failure to do so may result in he collapse of the wall.

Rev	Description	By	Date	Chk'd

	Purpose of Issue	Rev	Date	Auth

CLP Structures
STRUCTURAL ENGINEERING CONSULTANTS
EMAIL: mail@CLP-Structures.co.uk
TEL: 0117 3706357

Client
Elite Precast Concrete Ltd.

Project
Dutch Barn

Title
5 Block High
Wall Design Options

Original Scale	Drawn	Rev – Checked
As noted	CEL	
	Date July 17	

Drawing Number
599–02

A3